

Our Ref: CR/JC

17 May 2007

Sigma Commerical Products Ltd
Units 7-8 Britannia Business Park
Comet Way
Southend on Sea
Essex
SS2 6GE

RECEIVED 25 MAY 2007

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

COATINGS, PAINTS & LININGS - FACTORY APPLIED - PIPE & FITTINGS COATINGS 5030

PPA 571 Blue 536. Polyolefin alloy coating. Cold water use only.

Test Report: MA3345/X

0610512


SIGMA COMMERCIAL PRODUCTS LTD

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in October 2011.

Yours faithfully


Chris Ramsey (Miss)
Materials Approval
Water Regulations Advisory Scheme